

# 2022 Water Quality Report for the Village of Paw Paw

Water Supply Serial Number: MI0005210

This report covers the drinking water quality for the Village of Paw Paw for the 2022 calendar year. This information is a snapshot of the quality of the water that we provided to you in 2022. Included are details about where your water comes from, what it contains, and how it compares to United States Environmental Protection Agency (U.S. EPA) and state standards.

Your water comes from three groundwater wells, each over 110, 160, and 178 feet deep. The State performed an assessment of our source water to determine the susceptibility or the relative potential of contamination. The susceptibility rating is on a seven-tiered scale from "very-low" to "very-high" based on geologic sensitivity, well construction, water chemistry and contamination sources. The susceptibility of our source is Moderately low for wells #6 & #8, and Moderately high for back-up Well #4.

There are no significant sources of contamination in our water supply. We are making efforts to protect our sources by participating in the State of Michigan Wellhead Protection Program and following the EGLE annual drinking water monitoring schedule.

If you would like to know more about the report, please contact Tim Brandys, Department of Public Services Director, 110 Harry L. Bush Blvd, Paw Paw, Michigan, 49079, phone number 269-657-3169. Copies are available at the Paw Paw Village Hall. The report is also posted on the Village's Website, [www.pawpaw.net](http://www.pawpaw.net) (click on the left hand menu item titled Public Services and then click on the item titled "Consumer Confidence Report 2022". This report is not being mailed to all water customers.

**Contaminants and their presence in water:** Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the U.S. EPA's Safe Drinking Water Hotline (800-426-4791).


**Vulnerability of sub-populations:** Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing

chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune systems disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. U.S. EPA/Center for Disease Control guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

**Sources of drinking water:** The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. Our water comes from wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

**Contaminants that may be present in source water include:**

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture and residential uses.
- **Radioactive contaminants**, which can be naturally occurring or be the result of oil and gas production and mining activities.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm water runoff, and septic systems.



In order to ensure that tap water is safe to drink, the U.S. EPA prescribes regulations that limit the levels of certain contaminants in water provided by public water systems. Federal Food and Drug Administration regulations establish limits for contaminants in bottled water which provide the same protection for public health.

## Water Quality Data

The table below lists all the drinking water contaminants that we detected during the 2022 calendar year. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. Unless otherwise noted, the data presented in this table is from testing done January 1, 2022 through December 31, 2022. The State allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants are not expected to vary significantly from year to year. All the data is representative of the water quality, but some are more than one year old.

### Terms and abbreviations used below:

- Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
- Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
- Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
- Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
- Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
- N/A: Not applicable
- ND: not detectable at testing limit
- ppm: parts per million or milligrams per liter
- ppb: parts per billion or micrograms per liter
- ppt: parts per trillion or nanograms per liter
- pCi/l: picocuries per liter (a measure of radioactivity)
- Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.
- Level 1 Assessment: A study of the water supply to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.
- Level 2 Assessment: A very detailed study of the water system to identify potential problems and determine (if possible) why an *E. coli* MCL violation has occurred and/or why total coliform bacteria have been found in our water system on multiple occasions.

1 Monitoring Data for Regulated Contaminants

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Arsenic (ppb)	10	0	4.6	4.6-4.6	2022	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes
Barium (ppm)	2	2	0.320	0.320-0.320	2022	No	Discharge of drilling wastes; Discharge of metal refineries; Erosion of natural deposits
Nitrate (ppm)	10	10	ND	NA	2021	No	Runoff from fertilizer use; Leaching from septic tanks, sewage; Erosion of natural deposits
Fluoride (ppm)	4	4	0.210	0.000-0.210	2022	No	Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories
Sodium <sup>1</sup> (ppm)	N/A	N/A	20.0	16.0-20.0	2022	No	Erosion of natural deposits
TTHM Total Trihalomethanes (ppb)	80	N/A	16	N/A	2022	No	Byproduct of drinking water disinfection
HAA5 Haloacetic Acids (ppb)	60	N/A	ND	N/A	2022	No	Byproduct of drinking water disinfection
Chlorine <sup>2</sup> (ppm)	4	4	0.37	0.18-0.79	202	No	Water additive used to control microbes
Alpha emitters (pCi/L)	15	0	1.3	0-1.3	2014	No	Erosion of natural deposits
Combined radium (pCi/L)	5	0	0.578	0.458-.578	2020	No	Erosion of natural deposits
Total Coliform (total number or % of positive samples/month)	TT	0	N/A	N/A	2022	No	Naturally present in the environment
E. coli in the distribution system (positive samples)	See E. coli note <sup>3</sup>	0	NA	N/A	2022	No	Human and animal fecal waste
Fecal Indicator – E. coli at the source (positive samples)	TT	0	NA	N/A	2022	No	Human and animal fecal waste

<sup>1</sup> Sodium is not a regulated contaminant. <sup>2</sup> The chlorine "Level Detected" was calculated using a running annual average. <sup>3</sup> E. coli MCL violation occurs if (1) routine and repeat samples are total coliform-positive and either is E. coli-positive or (2) the supply fails to take all required repeat samples following E. coli-positive routine sample, or (3) the supply fails to analyze total coliform-positive repeat sample for E. coli.

Per- and polyfluoroalkyl substances (PFAS)

Regulated Contaminant	MCL, TT, or MRDL	MCLG or MRDLG	Level Detected	Range	Year Sampled	Violation Yes/No	Typical Source of Contaminant
Hexafluoropropylene oxide dimer acid (HFPO-DA) (ppt)	370	N/A	ND	NA	2022	No	Discharge and waste from industrial facilities utilizing the Gen X chemical process
Perfluorobutane sulfonic acid (PFBS) (ppt)	420	N/A	ND	NA	2022	No	Discharge and waste from industrial facilities; stain-resistant treatments
Perfluorohexane sulfonic acid (PFHxS) (ppt)	51	N/A	ND	Na	2022	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorohexanoic acid (PFHxA) (ppt)	400,000	N/A	ND	NA	2022	No	Firefighting foam; discharge and waste from industrial facilities
Perfluorononanoic acid (PFNA) (ppt)	6	N/A	ND	NA	2022	No	Discharge and waste from industrial facilities; breakdown of precursor compounds
Perfluorooctane sulfonic acid (PFOS) (ppt)	16	N/A	ND	NA	2022	No	Firefighting foam; discharge from electroplating facilities; discharge and waste from industrial facilities
Perfluorooctanoic acid (PFOA) (ppt)	8	N/A	ND	NA	2022	NO	Discharge and waste from industrial facilities; stain-resistant treatments
Inorganic Contaminant Subject to Action Levels (AL)	Action Level	MCLG	Your Water <sup>4</sup>	Range of Results	Year Sampled	Number of Samples Above AL	Typical Source of Contaminant
Lead (ppb)	15	0	2	0-4	2022	0	Lead service lines, corrosion of household plumbing including fittings and fixtures; Erosion of natural deposits
Copper (ppm)	1.3	1.3	0.01	0-0.2	2022	0	Corrosion of household plumbing systems; Erosion of natural deposits

<sup>4</sup> Ninety (90) percent of the samples collected were at or below the level reported for our water.

Coliforms are bacteria that are naturally present in the environment and used as an indicator that other potentially harmful, waterborne pathogens may be present or that a potential pathway exists through which contamination may enter the drinking water distribution system. We found coliforms, indicating the need to look for potential problems in water treatment or distribution. When this occurs, we are required to conduct assessment(s) to identify problems and to correct the problems that were found during these assessments.

The Village of Paw Paw failed to public notice a violation for failure to monitor disinfectants that occurred in 2021 due by December 13, 2022. As a result, we received a violation for failure to public notice. EGLE established a new deadline of February 13, 2023. The Village of Paw Paw issued the public notice on January 27, 2023 delivered via mail and posted on the Village website on January 27, 2023. Our staff is making every effort to assure this does not happen again.

**Information about lead:** If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Paw Paw is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you have a lead service line it is recommended that you run your water for at least 5 minutes to flush water from both your home plumbing and the lead service line. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

Our water supply has an unknown number of lead service lines at this time. 515 service lines of are of unknown material out of a total of 1,120 service lines. In 2022, 605 services were investigated. Of the 605, 432 service lines were replaced and 173 were confirmed to be non-lead. This year and following years the Village has an aggressive program to continue service line investigation and replacement.

While your drinking water meets the U.S. EPA standard for arsenic, it does contain low levels of arsenic. The U.S. EPA standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. EPA continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

**Monitoring and Reporting to the DEQ Requirements:** The State and EPA require us to test our water on a regular basis to ensure its safety. We met all of the monitoring and reporting requirements for **2022**. We will update this report annually and will keep you informed of any problems that may occur throughout the year, as they happen. Copies are available at the Paw Paw Village Hall. The report is also posted on the Village's Website, [www.pawpaw.net](http://www.pawpaw.net) (click on the left hand menu item titled Public Services and then click on the item titled "Consumer Confidence Report **2022**". This report is not being mailed to all water customers.

We invite public participation in decisions that affect drinking water quality. You may contact the Village of Paw Paw Council, which meets the second and fourth Monday of every month at 7:30 p.m. at the Paw Paw District Library, 609 West Michigan, Paw Paw, Michigan. For more information about your water, or the contents of this report, contact Tim Brandys, Department of Public Services Director, 110 Harry L. Bush Blvd, Paw Paw, Michigan, 49079, phone number 269-657-3169. For more information about safe drinking water, visit the U.S. Environmental Protection Agency at [www.epa.gov/safewater/](http://www.epa.gov/safewater/).